



(C) PLD Designs 2011

Notes.

- [1] Values of P1, R4, R7 and P2, R5 and R6 depend on meter being driven. R4, R7, R5 and R6 are parallel combinations of, e.g. T_R4 and S_R4.
- [2] Position of solder blobs at SJ1 and SJ2 determine control direction of "preset" potentiometer P1 and P2 respectively.
- [3] SJ5 must be connected for the serial commands of the Chronulator software to work. It is connected to a manufacturer.
- [4] Processor version determines maximum frequency of the alternative X1A: ATmega168U-10AU: 8 MHz; ATmega168A-AU: 16 MHz.
- [5] SJ3 and SJ4 allow the current sources to be bypassed for alternative meter drive circuitry. Cut track to disable the sources.
- [6] C3A is meant to be an adjustable alternative to C3. A part such as Sprague-Goodman SGCS300, 8...30 pF, may be installed.
- [7] Values of C2 and C3 depend on selection of crystal.

PLD Designs Vancouver Island, British Columbia, Canada www.island.net/~kdbrown		b: (250) 390-4205 c: (250) 668-4209 pldd@uniserve.com
TITLE: chronSMD		
Document Number: 8026.1		REV: -4
Date: 21-Jun-2016 9:17:06 AM	Sheet: 1/1	